

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Health
Environmental Health Administration

Underground Storage Tank Division



Bureau of Hazardous Material

Brief Site description

Date: March 22, 2005

Subject: 1626 N. Capitol Street, NW (Former Firehouse)

In-house Reference Materials

1. EPA UST database-UST Access
2. DC LUST database
3. Case files specific for the address
4. UST Regulations 20DCMR, Chapter 55-70, October 1, 1999

As per EPA UST Access Database maintained within this division, there is no registered Underground Storage Tank (UST) System currently in service dispensing regulated substance; however a 550 gallons gasoline UST was removed on November 10, 1999. As per the inspection report the tank "was very corroded, pitted and had at least one hole at its bottom" indicating a potential release of hydrocarbons.

If developers encounter contaminated soil during the site development or due-diligent site assessment, RPs are obligated to report to Leaking Underground Storage Tank program for permitting, cleanup monitoring and oversight of complete cleanup related to former petroleum releases per the District's regulations. If you need any information, please contact 202 535 2525.

Prepared by:
Venkataiah Sreenivas, (DOH)
v.sreenivas@dc.gov